

# Emission Test Certificate

Monday 27<sup>th</sup> October 2025

**Manufacturer** Stonini Pty Ltd (Unit 5 /14 Anne St, Marys, NSW 27605, Australia).

**Product Name** Plaster Composite Wall Decorative Wall & Ceiling Panels 12mm Nominal Thickness.

**Date Tested** 10<sup>th</sup> October 2025 (Tested by FORAY Laboratories – NATA Accreditation 1231)

**Test Method** ASTM D5116:2025 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

**Emission Data (24 hrs):**

<b>Green Building Council of Australia</b> <b>Green Star Design &amp; As Built V1.3 - 13.1.2B &amp; 13.2</b> <b>Green Star Interiors V1.3 - 12.2</b>	<b>Plaster Composite Wall</b> <b>Decorative Wall &amp; Ceiling Panels</b>
Total Volatile Organic Compound (C <sub>6</sub> -C <sub>16</sub> ) Emission Rate Limit: ≤0.500 mg/m <sup>2</sup> /hr	Total Volatile Organic Compound (C <sub>6</sub> -C <sub>16</sub> ) Emission Rate: 0.072 mg/m <sup>2</sup> /hr
Formaldehyde Emission Rate Limit: ≤0.100 mg/m <sup>2</sup> /hr	Formaldehyde Emission Rate: 0.009 mg/m <sup>2</sup> /hr



Dr. Vyt Garnys  
PhD, BSc (Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Travis Hale  
BSc (Biotechnology)  
Senior Consultant



Dr. Tuan Duong  
PhD, B.Eng. (Chemical)  
Senior Consultant